

Repair and Preventative Maintenance RFP
Q&A
May 20, 2022

1. Where is the polyurethane sealer to be applied?

- a. Riverfront Garage; 1,050 linear feet. This will be applied at expansion joints and includes t-joints.